

Crime & Fire Log- Yr 2017

Date Reported	Incident		Incident	Location	Description of Incident	Disposition
	Date	Time				
04/25/17	04/10/17	1602	Identity Fraud	Allied Health Building	Student reports that another student used their name to create an email account.	Closed.
04/27/17	04/26/17	2327	Criminal Damaging or Endangering	4th & Waller St. Parking Lot	Student reports her vehicle window was damaged while parked in a campus housing parking lot.	Closed.
04/29/17	04/29/17	0013	Fire	Athletic Center exterior Founder's Plaza	Fire was extinguished, on the exterior mulch in raised planter, on the Founder's Plaza.	PFD and DPS responded. Cause of the fire-spontaneous combustion. All clear.
04/29/17	04/29/17	0240	Drug Paraphernalia Offenses/ Safety Hazard/ Criminal Mischief	Bridge View Court	Report of criminal mischief call leads to a campus housing apartment found to have drug paraphernalia and safety hazards.	DPS and RC responded. Referred to Residence Life for follow-up.
05/03/17	05/03/17	0830	Criminal Mischief	A-7 Parking lot	Vulgar note left on vehicle windshield.	Investigation pending.
05/05/17	05/05/17	1015	Theft	Campus View	Theft reported of speaker.	Investigation pending.
05/07/17	03/26/17	0145	Theft	Tanner Place	Theft reported in housing.	Investigation pending.
05/08/17	05/08/17	1355	Breaking and Entering	Off Campus Property leased by SSU	Unknown person broke into the baseball locker room.	Investigation pending.
05/13/17	05/13/17	1942	Alarm Activation	Campus View	Alarm activation. No smoke or flames present.	DPS and PFD responded. Cause of alarm-C/O alarm unknown. PFD cleared the building to reset panel.
05/18/17	05/18/17	1600	Alarm Activation	Campus View	Alarm activation. No smoke or flames present.	DPS and PFD responded. Cause of alarm-C/O caused by fumes from a power washer. All clear.
05/22/17	05/22/17	1625	Alarm Activation	Campus View	Alarm activation. Smoke present, no flames.	DPS and PFD responded. Cause of alarm-burnt food. All clear.
06/02/17	06/02/17	1638	Non-Criminal Incident	Administration outside Grounds	Smoldering mulch, without flame.	DPS extinguished smoldering mulch. All clear.
06/02/17	06/02/17	2120	Non-Criminal Incident	Administration outside Grounds	Smoldering mulch, without flame.	DPS and PFD extinguished smoldering mulch. All clear.

Crime & Fire Log- Yr 2017

Date Reported	Incident		Incident	Location	Description of Incident	Disposition
	Date	Time				
06/04/17	06/04/17	0725	Alarm Activation	Teacher Education Building	Alarm activation. No smoke or flames present.	DPS, maintenance and PFD responded. Cause of alarm-senor malfunction. All clear.
06/22/17	06/22/17	0033	Alarm Activation	Library	Alarm activation. No smoke or flames present.	DPS and PFD responded. Cause of alarm faulty heating element. Facilities Follow-up. PFD gave the clear.
06/24/17	06/24/17	1715	Alarm Activation	Campus View	Alarm activation. No smoke or flames present.	DPS and PFD responded. Cause of alarm-Pesticide fogger device. All clear.